


STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No.	MO-0040843
Owner:	City of Marshfield
Address:	798 S. Marshall Street, Marshfield, MO 65706
Continuing Authority:	Same as above
Address:	Same as above
Facility Name:	Marshfield WWTF
Facility Address:	325 Brinkley Road, Marshfield, MO 65706
Legal Description:	SE¼, Ne¼, Sec. 33, T31N, R18W, Webster County
Receiving Stream:	Unnamed Tributary to West Fork Niangua River (U)
First Classified Stream and ID:	West Fork Niangua River (P) (01175)
USGS Basin & Sub-watershed No.:	(10290110-010001)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 & #003 - POTW - SIC #4952

Stormwater clarifier.

Design flow is 3.92 MGD. Actual flow is dependent upon rainfall.

Outfall #002 – POTW – SIC #4952

Extended aeration / secondary clarifiers / tertiary filters / chlorination / sludge storage basins / sludge is land applied.

Design organic population equivalent is 10,000.

Design average daily flow is 1.5 million gallons per day.

Design sludge production is 210 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

September 21, 2001
Effective Date

June 23, 2006
(Revised)

A handwritten signature in black ink that reads "Doyle Childers".

Doyle Childers, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

September 20, 2006
Expiration Date
MO 780-0041 (10-93)

Cynthia S. Davies, Regional Director, Southwest Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					PAGE NUMBER 2 of 10	
					PERMIT NUMBER MO-0040843	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001 & #003</u> (Note 1)						
Flow	MGD	*		*	once/discharge/day	24 hr. estimate
Biochemical Oxygen Demand ₅	mg/L		45		once/discharge/week	24 hr. composite
Total Suspended Solids	mg/L		45		once/discharge/week	24 hr. composite
pH – Units	SU	****		****	once/discharge/week	grab
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY ; THE FIRST REPORT IS DUE AUGUST 28, 2006 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<u>Outfall #002</u>						
Flow	MGD	*		*	once/day**	24 hr. total
Biochemical Oxygen Demand ₅ ***	mg/L		15	10	once/week**	24 hr. composite
Total Suspended Solids***	mg/L		20	15	once/week**	24 hr. composite
pH – Units	SU	****		****	once/week**	grab
Fecal Coliform	#/100 ml	1000		400 (Note 2)	once/week**	grab
Total Residual Chlorine as Cl ₂	mg/L	0.01 (Note 3) (0.13 ML)		0.01 (Note 3) (0.13ML)	once/week**	grab
Ammonia as N, Total (Note 4) (May – October) (November – April)	mg/L	2.5 3.5		1.4 2.2	once/week**	grab
Temperature	°C	*		*	once/week**	grab
Oil & Grease	mg/L	20		15	once/month**	grab
Cyanide, Amenable to Chlorination	mg/L	0.005			once/month**	grab
Chromium, Total Recoverable	mg/L	0.042			once/month**	24 hr. composite
Copper, Total Recoverable	mg/L	0.037			once/month**	24 hr. composite
Lead, Total Recoverable	mg/L	0.029			once/month**	24 hr. composite
Zinc, Total Recoverable	mg/L	0.440			once/month**	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY ; THE FIRST REPORT IS DUE AUGUST 28, 2006 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
Whole Effluent Toxicity (WET) Test	% Survival	(See Special Conditions)			once/year in June	24 hr. composite
MONITORING REPORTS SHALL BE SUBMITTED ANNUALLY ; THE FIRST REPORT IS DUE OCTOBER 28, 2006 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					PAGE NUMBER 3 of 10	
					PERMIT NUMBER MO-0040843	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Upstream Monitoring</u> (Note 5)						
Copper, Dissolved	mg/L	*		*	once/quarter*****	grab
Ammonia as N	mg/L	*		*	once/quarter*****	grab
<u>Downstream Monitoring</u> (Note 6)						
Ammonia as N, Total (Note 4)	mg/L	*		*	once/quarter*****	grab
Cyanide, Amenable to Chlorination	mg/L	*		*	once/quarter*****	grab
Cadmium, Total	µg/L	*		*	once/quarter*****	grab
Chromium, Total	µg/L	*		*	once/quarter*****	grab
Copper, Total	µg/L	*		*	once/quarter*****	grab
Lead, Total	µg/L	*		*	once/quarter*****	grab
Temperature	°C	*		*	once/quarter*****	grab
pH – Units	SU	*		*	once/quarter*****	grab
MONITORING REPORTS SHALL BE SUBMITTED QUARTERLY ; THE FIRST REPORT IS DUE OCTOBER 28, 2006 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<u>Influent</u>						
Cyanide, Amenable to Chlorination	mg/L	*		*	once/quarter*****	grab
Cadmium, Total Recoverable	mg/L	*		*	once/quarter*****	grab
Chromium, Total Recoverable	mg/L	*		*	once/quarter*****	grab
Copper, Total Recoverable	mg/L	*		*	once/quarter*****	grab
Lead, Total Recoverable	mg/L	*		*	once/quarter*****	grab
Nickel, Total Recoverable	mg/L	*		*	once/quarter*****	grab
Zinc, Total Recoverable	mg/L	*		*	once/quarter*****	grab
MONITORING REPORTS SHALL BE SUBMITTED QUARTERLY ; THE FIRST REPORT IS DUE OCTOBER 28, 2006 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
B. STANDARD CONDITIONS						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only.
- ** Reports shall be submitted by the 28th day of the month following the reporting period, e.g. Reporting period is the month of March (samples collected weekday, weekly, or monthly), report due by April 28th.
- *** This facility is required to provide a 30-day average percent removal of at least 85.
- **** pH is measured in pH units and is not to be averaged. The pH for all facilities except lagoons is limited to the range of 6.0-9.0 pH units.
- ***** Sample once per quarter in the months of **January, April, July, and October**. Reports shall be submitted by the 28th day of the month following the reporting period, e.g. Reporting period is the 1st quarter (sample collected in April), report due by July 28th.

Note 1 - Discharge from Outfall #001 (stormwater clarifier) is permitted only when influent flow exceeds the wet weather design treatment flow capacity of the extended aeration plant.

Note 2 - Monthly average limit for Fecal Coliform is expressed as a geometric mean. Geometric mean for
 $n \text{ samples} = [a_1 \times a_2 \times a_3 \dots \times a_n]^{1/n}$

Note 3 - This permit contains a Total Residual Chlorine (TRC) limit.

- (a) This effluent limit is below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The department has determined the current acceptable ML for total residual chlorine to be 0.13 mg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 0.13 mg/L will be considered violations of the permit and values less than the minimum quantification level of 0.13 mg/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.
- (b) Disinfection is required year-round unless the permit specifically states that “Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31.” If your permit does not require disinfection during the non-recreational months, do not chlorinate in those months.
- (c) Do not chemically dechlorinate **if it is not needed to meet the limits in your permit**.
- (d) If no chlorine was used in a given sampling period, an actual analysis is not necessary. Simply report as “0 mg/L” TRC.

Note 4 - When samples are taken for ammonia analysis, pH and temperature measurements shall be taken at the same time.

Note 5 - Upstream monitoring of the receiving stream shall be performed above all outfalls and upstream of area affected by plant discharges.

Note 6 - Downstream monitoring of the receiving stream shall be performed at the point the stream leaves the Sewage Treatment Plant boundary.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:

- (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
- (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
- (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.

3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.

4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

5. Report as no-discharge when a discharge does not occur during the report period.

6. Water Quality Standards

- (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;

C. SPECIAL CONDITIONS (continued)

- (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
- (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.
8. The permittee shall submit a report semi-annually with the Discharge Monitoring Reports (**on January 28 and July 28**) which addresses measures taken to locate and eliminate sources of inflow and infiltration into the City's collection system.
9. The permittee shall notify the Department, in writing, of all system bypasses. See Standard Conditions, Part I, Section B.5. for additional details.
10. Permittee shall implement and enforce its approved pretreatment program in accordance with the requirements of 10 CSR 20-6.100. The approved program is hereby incorporated by reference.
11. As required in 40 CFR 122.21(j)(4), the permittee shall, as part of its renewal application for this permit, submit to the department a written technical evaluation of the need to revise local pretreatment under 40 CFR 403.5(c)(1).
12. Permittee shall submit to the Department on or before March 31st of each year a report briefly describing its pretreatment activities during the previous calendar year. At a minimum, the report shall include the following:
- (a) An updated list of the Permittee's Industrial Users, including their names and addresses, or a list of deletions and additions keyed to a previously submitted list. The Permittee shall provide a brief explanation of each deletion. This list shall identify which Industrial Users are subject to categorical pretreatment Standards and specify which Standards are applicable to each Industrial User. The list shall indicate which Industrial Users are subject to local standards that are more stringent than the categorical Pretreatment Standards. The Permittee shall also list the Industrial Users that are subject only to local requirements;
 - (b) A summary of the status of Industrial User compliance over the reporting period;
 - (c) A summary of compliance and enforcement activities (including inspections) conducted by the Permittee during the reporting period; and
 - (d) Any other relevant information requested by the Department.

C. SPECIAL CONDITIONS (continued)

13. Whole Effluent Toxicity (WET) tests shall be conducted as follows:

SUMMARY OF WET TESTING FOR THIS PERMIT				
OUTFALL	A.E.C. %	FREQUENCY	SAMPLE TYPE	MONTH
001	100	Annually	24 hr. composite	June

(a) Test Schedule and Follow-Up Requirements

- (1) Perform a single-dilution test in the months and at the frequency specified above. For tests which are successfully passed, submit test results using the department's WET test report form #MO-780-1899 along with complete copies of the test reports as received from the laboratory, including copies of chain-of-custody forms within 30 calendar days of availability to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102. If the effluent passes the test, do not repeat the test until the next test period.
 - a. For discharges of stormwater, samples shall be collected within three hours from when discharge first occurs.
 - b. Samples submitted for analysis of stormwater discharges shall be collected as a grab.
 - c. For discharges of non-stormwater, samples shall be collected only when precipitation has not occurred for a period of forty-eight hours prior to sample collection. In no event shall sample collection occur simultaneously with the occurrence of precipitation.
 - d. A twenty-four hour composite sample shall be submitted for analysis of non-stormwater discharges.
 - e. Upstream receiving water samples, where required, shall be collected upstream from any influence of the effluent where downstream flow is clearly evident.
 - f. Samples submitted for analysis of upstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
 - g. Chemical and physical analysis of the upstream control and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping.
 - h. Any and all chemical or physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% Effluent concentration in addition to analyses performed upon any other effluent concentration.
 - i. All chemical analyses included in the Missouri Department of Natural Resources WET test report form #MO-780-1899 shall be performed and results shall be recorded in the appropriate field of the report form.
 - j. Where flow-weighted composite sample is required for analysis, the samples shall be composited at the laboratory where the test is to be performed.
 - k. Where in stream testing is required downstream from the discharge, sample collection shall occur immediately below the established Zone of Initial Dilution in conjunction with or immediately following a release or discharge.
 - l. Samples submitted for analysis of downstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
- (2) All failing test results along with complete copies of the test reports as received from the laboratory, Including those tests conducted under condition (3) below, shall be reported to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the availability of the results.
- (3) If the effluent fails the test, a multiple dilution test shall be performed within 30 calendar days and biweekly thereafter, until one of the following conditions are met:
 - a. Three consecutive multiple-dilution tests pass. No further tests need to be performed until next regularly scheduled test period.
 - b. A total of three multiple-dilution tests fail.
- (4) Failure of at least three multiple-dilution tests during any period of accelerated monitoring violates the permit narrative requirement for aquatic life protection.

C. SPECIAL CONDITIONS (continued)

- (5) The permittee shall submit a CONCISE summary of all test results for the test series to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the third failed test.
- (6) Additionally, the following shall apply upon failure of the third MULTIPLE DILUTION test: A toxicity identification evaluation (TIE) or toxicity reduction evaluation (TRE) is automatically triggered. The permittee shall contact THE WATER PROTECTION PROGRAM within 14 calendar days from availability of the test results to ascertain as to whether a TIE or TRE is appropriate. The permittee shall submit a plan for conducting a TIE or TRE to the WATER PROTECTION PROGRAM within 60 calendar days of the date of DNR's direction to perform either a TIE or TRE. This plan must be approved by DNR before the TIE or TRE is begun. A schedule for completing the TIE or TRE shall be established in the plan approval.
- (7) Upon DNR's approval, the TIE/TRE schedule may be modified if toxicity is intermittent during the TIE/TRE investigations. A revised WET test schedule may be established by DNR for this period.
- (8) If a previously completed TIE has clearly identified the cause of toxicity, additional TIEs will not be required as long as effluent characteristics remain essentially unchanged and the permittee is proceeding according to a DNR approved schedule to complete a TRE and reduce toxicity. Regularly scheduled WET testing as required in the permit, without the follow-up requirements, will be required during this period.
- (9) When WET test sampling is required to run over one DMR period, each DMR report shall contain a copy of the department's WET test report form that was generated during the reporting period.
- (10) Submit a concise summary in tabular format of all test results with the annual report.

(b) PASS/FAIL procedure and effluent limitations:

- (1) To pass a single-dilution test, mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms or other federal guidelines as appropriate or required.
- (2) To pass a multiple-dilution test:
 - a. For facilities with a computed percent effluent at the edge of the zone of initial dilution, Allowable Effluent Concentration (AEC), OF 30% OR LESS THE AEC must be less than three-tenths (0.3) of the LC_{50} concentration for the most sensitive of the test organisms; **OR**,
 - b. For facilities with an AEC greater than 30% the LC_{50} concentration must be greater than 100%; **AND**,
 - c. All effluent concentrations equal to or less than the AEC must be nontoxic. Mortality observed in all effluent concentrations equal to or less than the AEC shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms or other federal guidelines as appropriate or required. Failure of one multiple-dilution test may be considered an effluent limit violation.

(c) Test Conditions

- (1) Test Type: Acute Static non-renewal
- (2) Test species: Ceriodaphnia dubia and Pimephales promelas (fathead minnow). Organisms used in WET testing shall come from cultures reared for the purpose of conducting toxicity tests and cultured in a manner consistent with the most current USEPA guidelines. All test animals shall be cultured as described in the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms.

C. SPECIAL CONDITIONS (continued)

- (3) Test period: 48 hours at the "Acceptable Effluent Concentration" (AEC) specified above.
- (4) When dilutions are required, upstream receiving stream water shall be used as dilution water. If upstream water is unavailable or if mortality in the upstream water exceeds 10%, "reconstituted" water will be used as dilution water. Procedures for generating reconstituted water will be supplied by the MDNR upon request.
- (5) Single-dilution tests will be run with:
 - a. Effluent at the AEC concentration;
 - b. 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
 - c. reconstituted water.
- (6) Multiple-dilution tests will be run with:
 - a. 100%, 50%, 25%, 12.5%, and 6.25% effluent, unless the AEC is less than 25% effluent, in which case dilutions will be 4 times the AEC, two times the AEC, AEC, 1/2 AEC and 1/4 AEC;
 - b. 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
 - c. reconstituted water.
- (7) If reconstituted-water control mortality for a test species exceeds 10%, the entire test will be rerun.
- (8) If upstream control mortality exceeds 10%, the entire test will be rerun using reconstituted water as the dilutant.

C. SPECIAL CONDITIONS (continued)

SUMMARY OF TEST METHODOLOGY FOR WHOLE-EFFLUENT TOXICITY TESTS

Whole-effluent-toxicity test required in NPDES permits shall use the following test conditions when performing single or multiple dilution methods. Any future changes in methodology will be supplied to the permittee by the Missouri Department of Natural Resources (MDNR). Unless more stringent methods are specified by the DNR, the procedures shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms.

Test conditions for Ceriodaphnia dubia:

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light, 8 h dark
Size of test vessel:	30 mL (minimum)
Volume of test solution:	15 mL (minimum)
Age of test organisms:	<24 h old
No. of animals/test vessel:	5
No. of replicates/concentration:	4
No. of organisms/concentration:	20 (minimum)
Feeding regime:	None (feed prior to test)
Aeration:	None
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$)
Test acceptability criterion:	90% or greater survival in controls

Test conditions for Pimephales promelas:

Test duration:	48 h
Temperature:	25 ± 1°C Temperatures shall not deviate by more than 3°C during the test.
Light Quality:	Ambient laboratory illumination
Photoperiod:	16 h light/ 8 h dark
Size of test vessel:	250 mL (minimum)
Volume of test solution:	200 mL (minimum)
Age of test organisms:	1-14 days (all same age)
No. of animals/test vessel:	10
No. of replicates/concentration:	4 (minimum) single dilution method 2 (minimum) multiple dilution method
No. of organisms/concentration:	40 (minimum) single dilution method 20 (minimum) multiple dilution method
Feeding regime:	None (feed prior to test)
Aeration:	None, unless DO concentration falls below 4.0 mg/L; rate should not exceed 100 bubbles/min.
Dilution water:	Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness.
Endpoint:	Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$)
Test Acceptability criterion:	90% or greater survival in controls